

**GOVERNMENT OF WEST BENGAL
OFFICE OF THE DIRECTOR GENERAL
WEST BENGAL FIRE & EMERGENCY SERVICES
13-D Mirza Ghalib Street, Kolkata- 700 016**

Memo No : IND/WB/FES/20192020/63200

DATE: 09/08/2019

**From :
The Director
Fire Prevention Wing,
West Bengal Fire & Emergency Services.**

**To :
INDUS VALLEY WORLD SCHOOL
488, AJAY NAGAR, E M BYPASS, NEAR PEERLESS HOSPITAL
Baisnabghata Patuli F. S., Purba Jadavpur,
Kolkata - 700094 .**

Sub :Renewal of Fire Safety Certificate for existing occupancy of a G+IV Storied under group Educational Building in the name and style of "Indus Valley World School" at the premises No. 488, Ajay Nagar, E. M. Bypass, Kolkata- 700094.

This is in reference to your Application No. IND/WB/FES/20192020/63200, dated 09/08/2019, regarding the Renewal of Fire Safety Certificate for existing occupancy of a G+IV Storied under group Educational Building in the name and style of "Indus Valley World School" at the premises No. 488, Ajay Nagar, E. M. Bypass, Kolkata- 700094..

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

1. Driveway must be free of any type of obstruction for easy movement of Fire Appliances
No parking will be allowed on the Drive way.
- 2 The Interior finish decoration of building shall be made with low flame spread material

confirming to the I.S. Specification

3. To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the building shall be strictly maintained.
4. Existing Electrical wiring of the whole building shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling & ducts.
5. A Fire control room shall have to be maintained which observe all the floors of the building.
6. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all vulnerable places of the building.
7. The employees and security staff shall be conversant with installed fire fighting equipments of the building and to operate in the event of fire and testing.
8. Mock Fire practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
9. Transformer, switch gear, main & meter room shall be protected with CO2 or DCP Fire extinguishers confirming I.S. specifications.
10. A crew of trained Firemen under an experienced officer shall be maintained round the clock for fire safety of the building.
11. First Aid fire fighting system shall be provided as per I.S. specifications.
12. Arrangement shall have to be made for regular checking, testing, and maintenance of all the Fire Fighting installation in the building to keep them in perfectly good working condition at all the times
13. If required the old electrical lines shall have to be replaced with new lines. The cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
14. Periodical flashing of water in the Hydrants pipe line shall be made to maintain the efficient working performance of above mentioned system.
15. The Fire Check Door shall be sealed with rubber sealing properly in order to prevent percolation of smoke.

16. Existing lift shall be treated as Fire Lift in case of emergency

17. The Fire Safety audit to be conducted at regular interval and to be recorded in the Fire Prevention maintenance register.

18. This Renewal of Fire Safety Certificate is valid for three (03) years from the date of issue of this letter and has to be renewed before expiry.

19. The certificate has to be obtained from the Director General, West Bengal Fire & Emergency Services regarding performance of all the Fire Safety arrangements and installations of the building.

Director
West Bengal Fire & Emergency Services

Signature valid
Digitally signed by RUMAR HADWIK
Date 2016.08.09 15:03:34 +05'30'

**GOVERNMENT OF WEST BENGAL
OFFICE OF THE DIRECTOR GENERAL
WEST BENGAL FIRE & EMERGENCY SERVICES
13-D Mirza Ghalib Street, Kolkata- 700 016**

Memo No : IND/WB/FES/20192020/62020

DATE: 30/07/2019

From :

The Director

Fire Prevention Wing,

West Bengal Fire & Emergency Services.

To :

Indus Valley World School

**488, Ajoy Nagar, Opp.- E. M. Bypass, Ward No.- 109, Borough No.- XII, P.S.- Purba
Jadavpur, Kolkata- 700094.**

**Baisnabghata Patuli F. S., Purba Jadavpur,
Kolkata - 700094 .**

**Sub :Renewal of Fire Safety Certificate for existing occupancy of a G+VII Storied under
group Educational Building in the name and style of "Indus Valley World School" at
the premises No. 488, Ajoy Nagar, Opp.- E. M. Bypass, Ward No.- 109, Borough No.-
XII, P.S.- Purba Jadavpur, Kolkata- 700094.**

This is in reference to your Application No. IND/WB/FES/20192020/62020, dated 30/07/2019,
regarding the Renewal of Fire Safety Certificate for existing occupancy of a G+VII Storied
under group Educational Building in the name and style of "Indus Valley World School" at the
premises No. 488, Ajoy Nagar, Opp.- E. M. Bypass, Ward No.- 109, Borough No.- XII, P.S.-
Purba Jadavpur, Kolkata- 700094..

The performance of the Fire Fighting System as incorporated in the buildings were tested at
random and found satisfactorily working condition. In view of the above this office is releasing
the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety
measures need to be incorporated / maintained.

1. Driveway must be free of any type of obstruction for easy movement of Fire Appliances.

No parking will be allowed on the Drive way.

2. The Interior finish decoration of building shall be made with low flame spread material confirming to the I.S. Specification.
3. To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the building shall be strictly maintained.
4. Existing Electrical wiring of the whole building shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling & ducts.
5. A Fire control room shall have to be maintained which observe all the floors of the building.
6. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all vulnerable places of the building.
7. The employees and security staff shall be conversant with installed fire fighting equipments of the building and to operate in the event of fire and testing.
8. Mock Fire practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
9. Transformer, switch gear, main & meter room shall be protected with CO2 or DCP Fire extinguishers confirming I.S. specifications.
10. A crew of trained Firemen under an experienced officer shall be maintained round the clock for fire safety of the building.
11. First Aid fire fighting system shall be provided as per I.S. specifications.
12. Arrangement shall have to be made for regular checking, testing, and maintenance of all the Fire Fighting installation in the building to keep them in perfectly good working condition at all the times.
13. If required the old electrical lines shall have to be replaced with new lines. The cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
14. Periodical flashing of water in the Hydrants and Sprinklers pipe line shall be made to maintain the efficient working performance of above mentioned system.

15. The Fire Check Door shall be sealed with rubber sealing properly in order to prevent percolation of smoke.
16. Existing lift shall be treated as Fire Lift in case of emergency.
17. The Fire Safety audit to be conducted at regular interval and to be recorded in the Fire Prevention maintenance register.
18. This Renewal of Fire Safety Certificate is valid for three (03) years from the date of issue of this letter and has to be renewed before expiry.
19. The certificate has to be obtained from the Director General, West Bengal Fire & Emergency Services regarding performance of all the Fire Safety arrangements and installations of the building.

Director
West Bengal Fire & Emergency Services

Signature valid
Digitally signed by RATAN
KUMAR HALDER
Date: 2019.07.30 11:37:55 IST